



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date : - No CCSC/9931/2024-25 dated 27.05.2024
Issued to : - The Principal,
Carmel Convent School
Sector - 9-B, Chandigarh
Quantity of sample : - Approximate 1200 ml.
Date of Collection : - 28-05-2024
Client reference : - Sample Collected by Laboratory Staff
Packing of sample : - Sample filled in P.P. and Glass Bottle
Source of sample : - from School tap of Carmel Convent School
Sector - 9-B, Chandigarh.

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.74
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	mg/l	0.9
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	92
7	Total Hardness (as CaCO ₃)	< 200	mg/l	80
8	Chloride (as Cl)	< 250	mg/l	4
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	137
11	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.05/2024-25/195366, dated 27.05.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/ 2068

Dated:- 31.05.2024

Chemist
M.C.P.H. Laboratory
Chandigarh

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Endst No. MCPH/24/.....

Dated :-31.05.2024

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.

sd/-

Chemist
M.C.P.H. Laboratory
Chandigarh

sd/-

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2024/ 7235

Dated:- 13/6/24

It is certified that an inspection team headed by Sh. Gulab Singh, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation, Chandigarh, inspected the Carmel Convent School, Sector 9-B, Chandigarh on 31.05.2024 and mentioned in inspection report that Carmel Convent School, Sector 9-B, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. This certificate is issued with the prior approval of competent authority, Municipal Corporation Chandigarh.

The above Certificate is valid for a period of One year w.e.f 31.05.2024 (i.e. Water Sampling Date)


Medical Officer of Health
Municipal Corporation
Chandigarh

To
Carmel Convent School,
Sector 9-B,
Chandigarh.